



Data Sheet

Form No.	Issue Date	Rev. Date
DS-4024	06/15/17	5/21/18

Eclipse GEN 2.0 Foam Generators:

Specify Eclipse GEN 2.0 Foam Generators as follows:

Voltage:

12 or 24

Controller (HMI):

Single Tellurus Panel

Dual Tellurus Panel

HMI Settings:

Default (*English*)

Number of Generators:

Two

Three

Generator Valve Type:

Elkhart

Generator Outlet Connection:

External 2 in. Victaulic with 1-1/2 in. FNPT internal threads

Generator 1 Hose Size:

(Hose size/panel connection to be used with Generator 1)

1.00 in. / 25 mm

1.50 in. / 38 mm

1.75 in. / 45 mm

2.00 in. / 50 mm

2.50 in. / 64 mm

Generator 2 Hose Size:

(Hose size/panel connection to be used with Generator 2)

1.00 in. / 25 mm

1.50 in. / 38 mm

1.75 in. / 45 mm

2.00 in. / 50 mm

2.50 in. / 64 mm

Generator 3 Hose Size:

(Hose size/panel connection to be used with Generator 2)

(Applicable only if Three Generators are ordered)

1.00 in. / 25 mm

1.50 in. / 38 mm

1.75 in. / 45 mm

2.00 in. / 50 mm

2.50 in. / 64 mm

High Rise (*Only selection if High Rise option is ordered*)

High Flow (*Only selection if High Flow option is ordered*)

The Following Items are Optional:

High Rise Option:

(Requires Three Generators to be ordered)

(Generator 3 operates at a higher discharge pressure)

Not Required *(Standard)*

With *(Optional)*

High Flow Option:

(Requires Three Generators to be ordered)

(Generator 3 flows at a higher capacity)

Not Required *(Standard)*

With *(Optional)*

Discharge Splitting Valve Option:

(Directs a single generator discharge to two locations)

Not Required *(Standard)*

With *(Optional)*